

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/02/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155479		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/27/2013	
NAME OF PROVIDER OR SUPPLIER KINGSTON CARE CENTER OF FORT WAYNE				STREET ADDRESS, CITY, STATE, ZIP CODE 1010 W WASHINGTON CENTER RD FORT WAYNE, IN 46825			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/24/13 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 03/27/13</p> <p>Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this PSR survey, Kingston Care Center of Fort Wayne was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and with 410 IAC 16.2. The original building consisting of the main entrance and the 100 hall was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and hard wired smoke detector in all resident rooms on the 200, 300 and 400 halls. Single station battery operated smoke detectors have been installed in all resident rooms on 100 hall. The facility has a capacity of 120 and had a census of 110 at the time of this survey.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/02/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155479	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/27/2013
NAME OF PROVIDER OR SUPPLIER KINGSTON CARE CENTER OF FORT WAYNE			STREET ADDRESS, CITY, STATE, ZIP CODE 1010 W WASHINGTON CENTER RD FORT WAYNE, IN 46825		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered except a detached storage building used for the storage of mowing equipment.	{K 000}			
{K 000}	Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 03/28/13. INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/24/13 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 03/27/13 Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040 Surveyor: Amy Kelley, Life Safety Code Specialist At this PSR survey, Kingston Care Center of Fort Wayne was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and with 410 IAC 16.2. The new section building consisting of the 200, 300 and 400 halls was surveyed with Chapter 18, New Health Care Occupancies. This one story facility was determined to be of Type V (111) construction and was fully	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/02/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155479	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/27/2013
NAME OF PROVIDER OR SUPPLIER KINGSTON CARE CENTER OF FORT WAYNE			STREET ADDRESS, CITY, STATE, ZIP CODE 1010 W WASHINGTON CENTER RD FORT WAYNE, IN 46825		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 2 sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and hard wired smoke detector in all resident rooms on the 200, 300 and 400 halls. Single station battery operated smoke detectors have been installed in all resident rooms on 100 hall. The facility has a capacity of 120 and had a census of 110 at the time of this survey. All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered except a detached storage building used for the storage of mowing equipment.	{K 000}			